

Risk Assessment ID

12

Fire Risk

Work Activity

General & Public

Nature of Risk

Fire

Group at Risk

All staff and members of the public

Brief Description

Fires can be caused as a result of various factors including electrical fault, inappropriate disposal of cigarettes, freak lightning in buildings, Arson and animal enclosures.

Probability

2

3 = Certain  
2 = Likely  
1 = Unlikely

Severity

3

3 = Major  
2 = Moderate  
1 = Minor

Risk Rating

6

6-9 = High  
4 = Medium  
1-3 = Low

Reduction Activity

- Follow fire & smoking policy – all staff trained and signed off during induction
- Serviceable fire extinguishers in all buildings.
- All fire escapes clearly labelled and designated fire assembly points in place.
- Weekly call point testing kept up to date.
- No Smoking signs in indoor areas including Tropical House, Activity Den, Pets Corner & Catering/Gift Shop.
- Designated areas for smoking.

Revised Probability

1

3 = Certain  
2 = Likely  
1 = Unlikely

Revised Severity

3

3 = Major  
2 = Moderate  
1 = Minor

Revised Risk Rating

3

6-9 = High  
4 = Medium  
1-3 = Low

Recommendations

- Regular checks on electrical equipment/serviceability.
- Continual staff training.

Name of Assessor/Reviewer

Lorraine Adams

Date of Assessment/Review

Reviewed Annually